

SCHOOL Birchwood Elementary School			DATE 6/2/2016			
TAG/ID	DESCRIPTION OF SOURCE	LOCATION	TIME	COLLECTOR	LEAD mg/L	Date Analyzed Lead
BE 1	Drinking Fountain	Room 105	3:06 AM	Ryan Bergami	<0.001	6/17/16
BE 2	Drinking Fountain	Room 104	3:08 AM	Ryan Bergami	<0.001	6/17/16
BE 3	Drinking Fountain	Room 101	3:10 AM	Ryan Bergami	<0.001	6/17/16
BE 4	Drinking Fountain	Room 107	3:13 AM	Ryan Bergami	<0.001	6/17/16
BE 5	Drinking Fountain	Room 108	3:15 AM	Ryan Bergami	0.0015	6/17/16
BE 6	Drinking Fountain	Room 109	3:17 AM	Ryan Bergami	0.011	6/17/16
BE 7	Drinking Fountain	Room 110	3:19 AM	Ryan Bergami	0.0019	6/17/16
BE 8	Drinking Fountain	Room 111	3:21 AM	Ryan Bergami	0.0049	6/17/16
BE 9	Faucet	Room 114	3:23 AM	Ryan Bergami	0.0016	6/17/16
BE 10	Drinking Fountain	Hallway Fountain	3:25 AM	Ryan Bergami	<0.001	6/17/16
BE 11	Drinking Fountain	Room 125	3:27 AM	Ryan Bergami	0.0059	6/17/16
BE 12	Drinking Fountain	Room 129	3:30 AM	Ryan Bergami	0.0043	6/17/16
BE 13	Drinking Fountain	Hallway Fountain	3:33 AM	Ryan Bergami	0.003	6/17/16
BE 14	Drinking Fountain	Room 138	3:36 AM	Ryan Bergami	0.0079	6/17/16
BE 15	Drinking Fountain	Room 139	3:38 AM	Ryan Bergami	<0.001	6/17/16
BE 16	Drinking Fountain	Room 141	3:40 AM	Ryan Bergami	<0.001	6/17/16
BE 17	Drinking Fountain	Room 140	3:42 AM	Ryan Bergami	0.0048	6/17/16
BE 18	Drinking Fountain	Room 143	3:44 AM	Ryan Bergami	<0.001	6/17/16
BE 19	Drinking Fountain	Room 142	3:45 AM	Ryan Bergami	0.002	6/17/16
BE 20	Drinking Fountain	Room 145	3:48 AM	Ryan Bergami	<0.001	6/17/16
BE 21	Drinking Fountain	Room 144	3:50 AM	Ryan Bergami	<0.001	6/17/16
BE 22	Drinking Fountain	Hallway Fountain	3:52 AM	Ryan Bergami	<0.001	6/17/16
BE 23	Drinking Fountain	Hallway Fountain	3:54 AM	Ryan Bergami	<0.001	6/17/16
BE 24	Drinking Fountain	Room 146	3:56 AM	Ryan Bergami	<0.001	6/17/16
BE 25	Drinking Fountain	Room 147	3:58 AM	Ryan Bergami	<0.001	6/17/16
BE 26	Drinking Fountain	Room 148	4:00 AM	Ryan Bergami	0.0025	6/17/16
BE 27	Drinking Fountain	Room 149	4:05 AM	Ryan Bergami	<0.001	6/17/16
BE 28	Faucet	Cafeteria Kitchen	4:10 AM	Ryan Bergami	0.01	6/17/16
BE 29	Faucet	Cafeteria Kitchen	4:11 AM	Ryan Bergami	0.0087	6/17/16

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action	Units
105 Sink	9/27/2016 05:04	10/10/2016 22:14	10364812001	Lead	0.89	15	ug/L
104 Sink	9/27/2016 05:05	10/10/2016 22:23	10364812002	Lead	0.78	15	ug/L
101 Sink	9/27/2016 05:06	10/10/2016 22:25	10364812003	Lead	1.3	15	ug/L
107 Sink	9/27/2016 05:06	10/10/2016 22:26	10364812004	Lead	1.9	15	ug/L
108 Sink	9/27/2016 05:07	10/10/2016 22:28	10364812005	Lead	3.0	15	ug/L
109 Sink	9/27/2016 05:10	10/10/2016 22:29	10364812006	Lead	16.7	15	ug/L
110 Sink	9/27/2016 05:10	10/10/2016 22:31	10364812007	Lead	3.0	15	ug/L
111 Sink	9/27/2016 05:11	10/10/2016 22:32	10364812008	Lead	13.2	15	ug/L
113 Sink	9/27/2016 05:13	10/10/2016 22:37	10364812009	Lead	1.7	15	ug/L
Sink Womens Front Hall	9/27/2016 05:14	10/10/2016 22:38	10364812010	Lead	2.9	15	ug/L
Sink Mens Front Hall	9/27/2016 05:16	10/10/2016 22:40	10364812011	Lead	4.2	15	ug/L
123A Nurse Sink	9/27/2016 05:10	10/10/2016 22:43	10364812012	Lead	8.3	15	ug/L
123A Nurse Bath Sink	9/27/2016 05:13	10/10/2016 22:44	10364812013	Lead	6.9	15	ug/L
125 Library	9/27/2016 05:19	10/10/2016 22:46	10364812014	Lead	1.3	15	ug/L
Cafeteria Hand Wash 119	9/27/2016 05:26	10/10/2016 22:47	10364812015	Lead	2.0	15	ug/L
126 Bath Ladies	9/27/2016 05:28	10/10/2016 22:49	10364812016	Lead	15.1	15	ug/L
126 Bath Mens	9/27/2016 05:28	10/10/2016 22:51	10364812017	Lead	20.0	15	ug/L
132 Sink Bath	9/27/2016 05:30	10/10/2016 22:55	10364812018	Lead	8.7	15	ug/L
129Sink	9/27/2016 05:31	10/10/2016 22:57	10364812019	Lead	4.3	15	ug/L
136A Sink	9/27/2016 05:30	10/10/2016 22:58	10364812020	Lead	12.8	15	ug/L
138 Sink	9/27/2016 05:38	10/12/2016 15:40	10364812021	Lead	2.8	15	ug/L
139 Bath	9/27/2016 05:40	10/12/2016 15:46	10364812022	Lead	7.1	15	ug/L
139 Class	9/27/2016 05:40	10/12/2016 15:47	10364812023	Lead	0.62	15	ug/L
140 Sink	9/27/2016 05:41	10/12/2016 15:48	10364812024	Lead	3.0	15	ug/L
141 Bath	9/27/2016 05:42	10/12/2016 15:50	10364812025	Lead	0.97	15	ug/L
141 Class	9/27/2016 05:42	10/12/2016 15:51	10364812026	Lead	0.47	15	ug/L
142 Sink	9/27/2016 05:43	10/12/2016 15:53	10364812027	Lead	0.93	15	ug/L
143 Bath	9/27/2016 05:45	10/12/2016 15:57	10364812028	Lead	6.4	15	ug/L
143 Class	9/27/2016 05:45	10/12/2016 15:58	10364812029	Lead	0.49	15	ug/L
144 Bath	9/27/2016 05:48	10/12/2016 16:00	10364812030	Lead	13.5	15	ug/L
144 Class	9/27/2016 05:48	10/12/2016 16:01	10364812031	Lead	0.49	15	ug/L
145 Bath	9/27/2016 05:50	10/13/2016 00:27	10364812032	Lead	306	15	ug/L
145 Class	9/27/2016 05:50	10/12/2016 16:02	10364812033	Lead	1.8	15	ug/L
Coner Bath	9/27/2016 05:53	10/12/2016 16:04	10364812034	Lead	5.5	15	ug/L
Next 156 Bath	9/27/2016 05:55	10/12/2016 16:05	10364812035	Lead	3.1	15	ug/L
146 Bath	9/27/2016 05:57	10/12/2016 16:06	10364812036	Lead	2.7	15	ug/L
146 Class	9/27/2016 05:57	10/12/2016 16:08	10364812037	Lead	2.7	15	ug/L
147 Bath	9/27/2016 06:00	10/12/2016 16:10	10364812038	Lead	2.9	15	ug/L
147 Class	9/27/2016 06:00	10/12/2016 16:15	10364812039	Lead	1.6	15	ug/L
148 Bath	9/27/2016 06:02	10/12/2016 16:16	10364812040	Lead	0.76	15	ug/L
148 Class	9/27/2016 06:02	10/6/2016 20:39	10364812041	Lead	7.8	15	ug/L
149 Bath	9/27/2016 06:03	10/6/2016 20:42	10364812042	Lead	1.6	15	ug/L
149 Class	9/27/2016 06:03	10/6/2016 20:45	10364812043	Lead	3.4	15	ug/L
150 Bath	9/27/2016 06:05	10/6/2016 20:48	10364812044	Lead	5.7	15	ug/L
150 Class	9/27/2016 06:05	10/6/2016 20:51	10364812045	Lead	10.7	15	ug/L
Out Corner PlayGround	9/27/2016 06:07	10/6/2016 20:54	10364812046	Lead	14.8	15	ug/L
Out Corner Ball Field	9/27/2016 06:10	10/6/2016 21:03	10364812047	Lead	66.2	15	ug/L
Out Corner By 22	9/27/2016 06:10	10/6/2016 21:06	10364812048	Lead	270	15	ug/L
Out Corner By 20	9/27/2016 06:13	10/13/2016 00:28	10364812049	Lead	833	15	ug/L
Outdoor By 8	9/27/2016 06:17	10/6/2016 21:09	10364812050	Lead	7.3	15	ug/L
Outdoor By 4	9/27/2016 06:25	10/6/2016 21:12	10364812051	Lead	2.7	15	ug/L

Outdoor By Kitchen	9/27/2016 06:30	10/6/2016 21:15	10364812052	Lead	29.8	15	ug/L
--------------------	-----------------	-----------------	-------------	------	------	----	------

NYSDOH Action Level for Lead of 15 ppb