

SCHOOL Craig Elementary School			DATE 6/7/2016			
TAG/ID	DESCRIPTION OF SOURCE	LOCATION	TIME	COLLECTOR	LEAD mg/L	Date Analyzed Lead
CE 1	Faucet	Room 46	2:49 AM	Ryan Bergami	0.0013	6/28/16
CE 2	Drinking Fountain	Room 45	2:52 AM	Ryan Bergami	<0.001	6/28/16
CE 3	Faucet	Room 43	2:54 AM	Ryan Bergami	0.0014	6/28/16
CE 4	Faucet	Room 42	2:56 AM	Ryan Bergami	<0.001	6/28/16
CE 5	Drinking Fountain	Room 37	2:59 AM	Ryan Bergami	0.0057	6/28/16
CE 6	Drinking Fountain	Room 38	3:01 AM	Ryan Bergami	0.0063	6/28/16
CE 7	Drinking Fountain	Room 35	3:04 AM	Ryan Bergami	0.0027	6/28/16
CE 8	Drinking Fountain	Room 34	3:06 AM	Ryan Bergami	0.0032	6/28/16
CE 9	Drinking Fountain	Room 33	3:09 AM	Ryan Bergami	0.0042	6/28/16
CE 10	Drinking Fountain	Room 32	3:11 AM	Ryan Bergami	0.0012	6/28/16
CE 11	Drinking Fountain	Room 27	3:15 AM	Ryan Bergami	<0.001	6/28/16
CE 12	Drinking Fountain	Room 26	3:17 AM	Ryan Bergami	<0.001	6/28/16
CE 13	Drinking Fountain	Room 25	3:19 AM	Ryan Bergami	<0.001	6/28/16
CE 14	Drinking Fountain	Room 24	3:22 AM	Ryan Bergami	<0.001	6/28/16
CE 15	Drinking Fountain	Room 23	3:23 AM	Ryan Bergami	<0.001	6/28/16
CE 16	Drinking Fountain	Room 22	3:25 AM	Ryan Bergami	<0.001	6/28/16
CE 17	Drinking Fountain	Room 21	3:27 AM	Ryan Bergami	<0.001	6/28/16
CE 18	Drinking Fountain	Room 18	3:29 AM	Ryan Bergami	<0.001	6/28/16
CE 19	Drinking Fountain	Room 16	3:31 AM	Ryan Bergami	0.0039	6/28/16
CE 20	Drinking Fountain	Room 13	3:34 AM	Ryan Bergami	<0.001	6/28/16
CE 21	Drinking Fountain	Room 12	3:36 AM	Ryan Bergami	<0.001	6/28/16
CE 22	Drinking Fountain	Room 11	3:38 AM	Ryan Bergami	<0.001	6/28/16
CE 23	Drinking Fountain	Room 8	3:40 AM	Ryan Bergami	<0.001	6/28/16
CE 24	Drinking Fountain	Room 10	3:41 AM	Ryan Bergami	<0.001	6/28/16
CE 25	Drinking Fountain	Room 9	3:42 AM	Ryan Bergami	<0.001	6/28/16
CE 26	Drinking Fountain	Hallway Fountain	3:44 AM	Ryan Bergami	<0.001	6/28/16
CE 27	Drinking Fountain	Cafeteria	3:47 AM	Ryan Bergami	<0.001	6/28/16
CE 28	Faucet	Kitchen sink	3:50 AM	Ryan Bergami	0.0022	6/28/16
CE 29	Faucet	Kitchen sink	3:53 AM	Ryan Bergami	0.0059	6/28/16
CE 30	Faucet	Room 48	3:55 AM	Ryan Bergami	0.001	6/28/16

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
OUT EAST SPIGOT	9/28/2016 05:05	10/25/2016 19:55	10366752001	Lead	86.4	15	ug/L
OUT NORTH SPIGOT	9/28/2016 05:10	11/1/2016 17:52	10366752002	Lead	41.0	15	ug/L
26 CLASS SINK	9/28/2016 05:15	10/25/2016 20:02	10366752003	Lead	1.2	15	ug/L
26 BATH SINK	9/28/2016 05:15	10/25/2016 20:03	10366752004	Lead	0.9	15	ug/L
25 CLASS SINK	9/28/2016 05:17	10/25/2016 20:04	10366752005	Lead	0.76	15	ug/L
25 BATH SINK	9/28/2016 05:17	10/25/2016 20:05	10366752006	Lead	0.83	15	ug/L
24 CLASS SINK	9/28/2016 06:19	10/25/2016 20:07	10366752007	Lead	1.8	15	ug/L
24 BATH SINK	9/28/2016 06:19	10/25/2016 20:08	10366752008	Lead	0.58	15	ug/L
27 CLASS SINK	9/28/2016 05:20	10/25/2016 20:09	10366752009	Lead	0.79	15	ug/L
27 BATH SINK	9/28/2016 05:20	10/25/2016 20:10	10366752010	Lead	0.68	15	ug/L
NEW WING WOMENS SINK	9/28/2016 05:22	10/25/2016 20:11	10366752011	Lead	1.7	15	ug/L
NEW WING MENS SINK	9/28/2016 05:22	10/25/2016 20:15	10366752012	Lead	0.52	15	ug/L
COURTYARD EAST SPIGOT	9/28/2016 05:26	10/25/2016 20:17	10366752013	Lead	11.8	15	ug/L
COURTYARD SOUTH SPIGOT	9/28/2016 05:28	10/25/2016 20:18	10366752014	Lead	8.3	15	ug/L
23 SINK	9/28/2016 05:33	10/25/2016 20:20	10366752015	Lead	1.5	15	ug/L
22 SINK	9/28/2016 05:34	10/25/2016 20:21	10366752016	Lead	1.5	15	ug/L
21 SINK	9/28/2016 05:30	10/25/2016 20:22	10366752017	Lead	0.79	15	ug/L
18 SINK	9/28/2016 05:38	10/25/2016 20:23	10366752018	Lead	0.7	15	ug/L
16 SINK	9/28/2016 05:40	10/25/2016 20:24	10366752019	Lead	2.2	15	ug/L
BATH HALL NR 14 SINK	9/28/2016 05:41	10/25/2016 20:26	10366752020	Lead	1.4	15	ug/L
14 SINK	9/28/2016 05:42	10/25/2016 16:53	10366752021	Lead	3.9	15	ug/L
13 SINK	9/28/2016 05:43	10/25/2016 16:57	10366752022	Lead	1.0	15	ug/L
4 GYM SINK	9/28/2016 05:45	10/25/2016 16:58	10366752023	Lead	3.8	15	ug/L
12 SINK	9/28/2016 05:47	10/25/2016 17:00	10366752024	Lead	1.5	15	ug/L
11 SINK	9/28/2016 05:48	10/25/2016 17:01	10366752025	Lead	1.6	15	ug/L
10 SINK	9/28/2016 05:50	10/25/2016 17:07	10366752026	Lead	1.2	15	ug/L
9 SINK	9/28/2016 05:51	10/25/2016 17:08	10366752027	Lead	1.0	15	ug/L
8 SINK	9/28/2016 05:52	10/25/2016 17:09	10366752028	Lead	1.5	15	ug/L
54 SINK	9/28/2016 05:55	10/25/2016 17:10	10366752029	Lead	1.8	15	ug/L
BATH WOMENS NR 54 (LEFT)	9/28/2016 05:58	10/25/2016 17:11	10366752030	Lead	0.38	15	ug/L
BATH WOMENS NR 54 (RIGHT)	9/28/2016 05:58	10/25/2016 17:12	10366752031	Lead	1.6	15	ug/L
BATH MENS RR 54	9/28/2016 06:00	10/25/2016 17:14	10366752032	Lead	0.53	15	ug/L
39 CLASS SINK	9/28/2016 06:02	10/25/2016 17:15	10366752033	Lead	6.6	15	ug/L
36 BATH SINK	9/28/2016 06:04	10/25/2016 17:17	10366752034	Lead	4.2	15	ug/L
34 BATH SINK	9/28/2016 06:05	10/25/2016 17:20	10366752035	Lead	3.0	15	ug/L
32 BATH SINK	9/28/2016 06:06	10/25/2016 17:21	10366752036	Lead	2.2	15	ug/L
33 BATH SINK LEFT (MEN)	9/28/2016 06:11	10/25/2016 17:22	10366752037	Lead	2.0	15	ug/L
33 BATH SINK LEFT (WOM)	9/28/2016 06:11	10/25/2016 17:24	10366752038	Lead	1.6	15	ug/L
35 BATH SINK	9/28/2016 06:12	10/25/2016 17:25	10366752039	Lead	4.7	15	ug/L
37 BATH SINK	9/28/2016 06:13	10/25/2016 17:26	10366752040	Lead	3.0	15	ug/L
43 BATH SINK	9/28/2016 06:20	11/4/2016 12:30	10366752041	Lead	1.1	15	ug/L
CAFETERIA HAND 1 (LEFT)	9/28/2016 06:25	11/4/2016 12:32	10366752042	Lead	3.5	15	ug/L
CAFETERIA HAND 2 (MID)	9/28/2016 06:25	11/4/2016 12:33	10366752043	Lead	1.5	15	ug/L
CAFETERIA HAND 3 (RIGHT)	9/28/2016 06:25	11/4/2016 12:36	10366752044	Lead	1.5	15	ug/L
2 SINK (ROOM)	9/28/2016 06:30	11/4/2016 12:37	10366752045	Lead	0.98	15	ug/L
1 SINK	9/28/2016 06:32	11/4/2016 12:38	10366752046	Lead	2.6	15	ug/L
OUTSIDE WEST NR ART RM	9/28/2016 06:32	11/4/2016 16:02	10366752047	Lead	423	15	ug/L
KITCHEN SPRAY	9/28/2016 06:34	11/4/2016 12:40	10366752048	Lead	6.2	15	ug/L
OUTSIDE NR KITCHEN	9/28/2016 06:40	11/4/2016 12:41	10366752049	Lead	0.72	15	ug/L