

SCHOOL Hillside Elementary School			DATE 6/7/2016			
TAG/ID	DESCRIPTION OF SOURCE	LOCATION	TIME	COLLECTOR	LEAD mg/L	Date Analyzed
HE 1	Drinking Fountain	Hallway Fountain	4:05 AM	Ryan Bergami	0.0047	6/28/16
HE 2	Faucet	Room 221	4:07 AM	Ryan Bergami	0.0013	6/28/16
HE 3	Drinking Fountain	Room 215	4:10 AM	Ryan Bergami	<0.001	6/28/16
HE 4	Drinking Fountain	Room 213	4:12 AM	Ryan Bergami	0.0017	6/28/16
HE 5	Drinking Fountain	Room 211	4:14 AM	Ryan Bergami	0.0024	6/28/16
HE 6	Drinking Fountain	Room 210	4:15 AM	Ryan Bergami	0.0012	6/28/16
HE 7	Drinking Fountain	Room 209	4:16 AM	Ryan Bergami	0.0012	6/28/16
HE 8	Drinking Fountain	Room 208	4:18 AM	Ryan Bergami	0.0017	6/28/16
HE 9	Drinking Fountain	Room 207	4:20 AM	Ryan Bergami	0.0017	6/28/16
HE 10	Drinking Fountain	Room 206	4:21 AM	Ryan Bergami	0.0022	6/28/16
HE 11	Drinking Fountain	Room 205	4:22 AM	Ryan Bergami	0.0028	6/28/16
HE 12	Drinking Fountain	Room 204	4:25 AM	Ryan Bergami	0.0025	6/28/16
HE 13	Drinking Fountain	Room 203	4:26 AM	Ryan Bergami	0.0037	6/28/16
HE 14	Drinking Fountain	Room 202	4:28 AM	Ryan Bergami	<0.001	6/28/16
HE 15	Drinking Fountain	Room 201	4:29 AM	Ryan Bergami	<0.001	6/28/16
HE 16	Drinking Fountain	Room 200	4:31 AM	Ryan Bergami	<0.001	6/28/16
HE 17	Faucet	Room 102	4:33 AM	Ryan Bergami	0.0017	6/28/16
HE 18	Drinking Fountain	Hallway Fountain	4:35 AM	Ryan Bergami	0.003	6/28/16
HE 19	Drinking Fountain	Room 123A	4:37 AM	Ryan Bergami	<0.001	6/28/16
HE 20	Drinking Fountain	Room 122	4:40 AM	Ryan Bergami	0.0023	6/28/16
HE 21	Faucet	Room 121	4:43 AM	Ryan Bergami	0.016	6/28/16
HE 22	Drinking Fountain	Room 120	4:44 AM	Ryan Bergami	<0.001	6/28/16
HE 23	Drinking Fountain	Room 117	4:46 AM	Ryan Bergami	<0.001	6/28/16
HE 24	Drinking Fountain	Hallway Fountain	4:53 AM	Ryan Bergami	<0.001	6/28/16
HE 25	Drinking Fountain	Hallway Fountain	4:54 AM	Ryan Bergami	<0.001	6/28/16
HE 26	Drinking Fountain	Hallway Fountain	4:57 AM	Ryan Bergami	<0.001	6/28/16
HE 27	Drinking Fountain	Hallway Fountain	4:58 AM	Ryan Bergami	<0.001	6/28/16
HE 28	Drinking Fountain	Room 133	5:00 AM	Ryan Bergami	<0.001	6/28/16
HE 29	Drinking Fountain	Room 137	5:02 AM	Ryan Bergami	<0.001	6/28/16
HE 30	Drinking Fountain	Room 134	5:04 AM	Ryan Bergami	<0.001	6/28/16
HE 31	Drinking Fountain	Room 136	5:05 AM	Ryan Bergami	<0.001	6/28/16
HE 32	Drinking Fountain	Room 135	5:07 AM	Ryan Bergami	<0.001	6/28/16
HE 33	Drinking Fountain	Cafeteria	5:12 AM	Ryan Bergami	<0.001	6/28/16
HE 34	Faucet	Kitchen Sink	5:16 AM	Ryan Bergami	0.0036	6/28/16
HE 35	Faucet	Kitchen Sink	5:17 AM	Ryan Bergami	0.0084	6/28/16
HE 36	Faucet	Room 112	5:21 AM	Ryan Bergami	<0.001	6/28/16
HE 37	Faucet	Room 112	5:21 AM	Ryan Bergami	<0.001	6/28/16

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
NHE001- Cafeteria (Sink) #1	9/29/2016 05:28	10/11/2016 19:50	10365409001	Lead	2.1	15	ug/L
NHE002- Cafeteria (Sink) #2	9/29/2016 05:28	10/11/2016 20:00	10365409002	Lead	1.4	15	ug/L
NHE003- Cafeteria (Sink) #3	9/29/2016 05:29	10/11/2016 20:02	10365409003	Lead	1.4	15	ug/L
NHE004- Nurse's Office (Sink)	9/29/2016 05:33	10/11/2016 20:04	10365409004	Lead	2.7	15	ug/L
NHE005- Nurse's Bathrm (Sink)	9/29/2016 05:34	10/11/2016 20:05	10365409005	Lead	2.8	15	ug/L
NHE006- Bathroom #1 (Sink)	9/29/2016 05:40	10/11/2016 20:07	10365409006	Lead	3.0	15	ug/L
NHE007- Bathroom #2 (Sink)	9/29/2016 05:40	10/11/2016 20:08	10365409007	Lead	4.3	15	ug/L
NHE008- Library Bathrm (Sink)	9/29/2016 05:44	10/11/2016 20:10	10365409008	Lead	0.79	15	ug/L
NHE009- Faculty Bathrm(Sink)#1	9/29/2016 05:45	10/11/2016 20:11	10365409009	Lead	1.3	15	ug/L
NHE010- Faculty Lounge(Sink)	9/29/2016 05:48	10/11/2016 20:16	10365409010	Lead	1.8	15	ug/L
NHE011 Music Rm 211/213 Sink#1	9/29/2016 05:49	10/11/2016 20:17	10365409011	Lead	2.1	15	ug/L
NHE012 Music Rm 211/213 Sink#2	9/29/2016 06:04	10/11/2016 20:20	10365409012	Lead	1.5	15	ug/L
NHE013- Rm. 209 (Sink)	9/29/2016 06:06	10/11/2016 20:22	10365409013	Lead	2.1	15	ug/L
NHE014- Rm. 210 (Sink)	9/29/2016 06:10	10/11/2016 20:23	10365409014	Lead	2.3	15	ug/L
NHE015- Rm. 207 (Sink)	9/29/2016 06:12	10/11/2016 20:25	10365409015	Lead	2.0	15	ug/L
NHE016- Rm. 208 (Sink)	9/29/2016 06:15	10/11/2016 20:26	10365409016	Lead	2.1	15	ug/L
NHE017- Rm. 205 (Sink)	9/29/2016 06:17	10/11/2016 20:28	10365409017	Lead	3.1	15	ug/L
NHE018- Rm. 206 (Sink)	9/29/2016 06:19	10/11/2016 20:29	10365409018	Lead	2.1	15	ug/L
NHE019- Rm. 203 (Sink)	9/29/2016 06:21	10/11/2016 20:34	10365409019	Lead	3.8	15	ug/L
NHE020- Rm. 204 (Sink)	9/29/2016 06:26	10/11/2016 20:35	10365409020	Lead	3.2	15	ug/L
NHE021- Rm. 202 (Sink)	9/29/2016 06:29	10/12/2016 00:42	10365409021	Lead	0.69	15	ug/L
NHE022- Rm. 201 (Sink)	9/29/2016 06:30	10/12/2016 00:54	10365409022	Lead	0.58	15	ug/L
NHE023- Rm. 200 (Sink)	9/29/2016 06:31	10/12/2016 00:57	10365409023	Lead	0.76	15	ug/L
NHE024- Art Rm 112 Brm (Sink)	9/29/2016 06:34	10/12/2016 01:00	10365409024	Lead	6.0	15	ug/L
NHE025- Art Rm. 112 (Sink) #1	9/29/2016 06:35	10/12/2016 01:03	10365409025	Lead	7.9	15	ug/L
NHE026- Art Rm. 112 (Sink) #2	9/29/2016 06:35	10/12/2016 01:06	10365409026	Lead	1.1	15	ug/L
NHE027- Art Rm. 112 (Sink) #3	9/29/2016 06:36	10/12/2016 01:09	10365409027	Lead	6.7	15	ug/L
NHE028- Art Rm. 112 (Sink) #4	9/29/2016 06:36	10/12/2016 01:18	10365409028	Lead	7.0	15	ug/L
NHE029- Art Rm. 112 (Sink) #5	9/29/2016 06:37	10/12/2016 01:21	10365409029	Lead	1.0	15	ug/L
NHE030- Art Rm. 112 (Sink) #6	9/29/2016 06:38	10/12/2016 01:24	10365409030	Lead	5.3	15	ug/L
NHE031- Faculty Bathrm(Sink)#2	9/29/2016 06:40	10/12/2016 01:27	10365409031	Lead	5.6	15	ug/L
NHE032- Broiler Rm (Sink)	9/29/2016 06:41	10/12/2016 01:30	10365409032	Lead	5.6	15	ug/L
NHE033- Maint Bathrm (Sink)	9/29/2016 06:41	10/12/2016 01:33	10365409033	Lead	3.7	15	ug/L
NHE034- Rm. 117 (Sink)	9/29/2016 06:44	10/12/2016 01:36	10365409034	Lead	1.8	15	ug/L
NHE035- Cust Closet (Sink) #1	9/29/2016 06:46	10/12/2016 01:39	10365409035	Lead	1.2	15	ug/L
NHE036- Cust Closet #2	9/29/2016 06:46	10/12/2016 01:42	10365409036	Lead	1.5	15	ug/L
NHE037- Rm 120 (Sink)	9/29/2016 06:48	10/12/2016 01:45	10365409037	Lead	9.5	15	ug/L
NHE038- Pysch. Rm. (Sink)	9/29/2016 06:49	10/12/2016 01:54	10365409038	Lead	10.1	15	ug/L
NHE039- Rm. 122 (Sink)	9/29/2016 06:50	10/12/2016 01:57	10365409039	Lead	2.1	15	ug/L
NHE040- Rm. 124 (Sink)	9/29/2016 06:50	10/12/2016 02:00	10365409040	Lead	1.3	15	ug/L
NHE041- Rm. 126 (Sink)	9/29/2016 06:51	10/12/2016 02:12	10365409041	Lead	1.3	15	ug/L
NHE042- Rm. 102 (Sink)	9/29/2016 06:52	10/12/2016 02:30	10365409042	Lead	2.7	15	ug/L
NHE043- Bath Rm. #3 (Sink)	9/29/2016 06:53	10/12/2016 02:33	10365409043	Lead	0.68	15	ug/L
NHE044- Bath Rm. #4 (Sink)	9/29/2016 06:55	10/12/2016 02:36	10365409044	Lead	1.2	15	ug/L
NHE045- Facult BathRm #3(Sink)	9/29/2016 06:55	10/12/2016 02:39	10365409045	Lead	0.8	15	ug/L
NHE046- Rm. 133 (Sink)	9/29/2016 06:56	10/12/2016 02:42	10365409046	Lead	1.2	15	ug/L
NHE047- Rm. 133 BathRm. Sink	9/29/2016 06:57	10/12/2016 02:45	10365409047	Lead	1.5	15	ug/L
NHE048- RM. 134 (Sink)	9/29/2016 06:59	10/12/2016 02:48	10365409048	Lead	1.4	15	ug/L
NHE049- Rm. 134 Bath Rm (Sink)	9/29/2016 07:00	10/12/2016 02:51	10365409049	Lead	1.3	15	ug/L
NHE050- Rm. 135 (Sink)	9/29/2016 07:01	10/12/2016 02:54	10365409050	Lead	1.4	15	ug/L
NHE051- Rm. 135 Bath Rm (Sink)	9/29/2016 07:01	10/12/2016 02:57	10365409051	Lead	1.3	15	ug/L

NHE052- Rm. 136 (Sink)	9/29/2016 07:03	10/12/2016 03:06	10365409052	Lead	1.5	15	ug/L
NHE053- Rm. 136 Bath Rm (Sink)	9/29/2016 07:03	10/12/2016 03:09	10365409053	Lead	1.2	15	ug/L
NHE054- Rm. 137 (Sink)	9/29/2016 07:04	10/12/2016 03:12	10365409054	Lead	1.1	15	ug/L
NHE055- Rm. 137 Bath Rm (Sink)	9/29/2016 07:05	10/12/2016 03:15	10365409055	Lead	1.1	15	ug/L
NHE056- Cust Closet #2 (Sink)	9/29/2016 07:06	10/12/2016 03:18	10365409056	Lead	2.1	15	ug/L
NHE057- Cust Closet #2 Hose	9/29/2016 07:08	10/12/2016 03:21	10365409057	Lead	1.9	15	ug/L
NHE058- Kitchen (Sink) #1	9/29/2016 07:10	10/12/2016 03:24	10365409058	Lead	3.5	15	ug/L
NHE059- Kitchen (Sink) #2 Hose	9/29/2016 07:10	10/12/2016 03:27	10365409059	Lead	7.5	15	ug/L
NHE060- Kitchen (Sink) #3	9/29/2016 07:10	10/12/2016 03:30	10365409060	Lead	5.2	15	ug/L
NHE061- Kitchen (Sink) #4	9/29/2016 07:11	10/10/2016 12:31	10365409061	Lead	6.6	15	ug/L
NHE062- Exterior Faucet #1	9/29/2016 07:14	10/10/2016 12:40	10365409062	Lead	13.6	15	ug/L
NHE063- Exterior Faucet #2	9/29/2016 07:15	10/10/2016 12:42	10365409063	Lead	24.5	15	ug/L
NHE064- Exterior Faucet #3	9/29/2016 07:15	10/10/2016 12:43	10365409064	Lead	13.3	15	ug/L
NHE065- Exterior Faucet #4	9/29/2016 07:15	10/10/2016 12:45	10365409065	Lead	50.0	15	ug/L

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm