

SCHOOL Niskayuna High School			DATE 6/9/2016			
TAG/ID	DESCRIPTION OF SOURCE	LOCATION	TIME	COLLECTOR	Lead mg/L	Date Analyzed
HS 1	Drinking Fountain	Hallway Fountain	3:49 AM	Ryan Bergami	<0.001	7/7/16
HS 2	Drinking Fountain	Hallway Fountain	3:52 AM	Ryan Bergami	0.0054	7/7/16
HS 3	Drinking Fountain	Cafeteria	3:55 AM	Ryan Bergami	<0.001	7/7/16
HS 4	Faucet	Room D262	3:59 AM	Ryan Bergami	<0.001	7/7/16
HS 5	Faucet	Room D262	4:00 AM	Ryan Bergami	<0.001	7/7/16
HS 6	Faucet	Room D262	4:01 AM	Ryan Bergami	<0.001	7/7/16
HS 7	Faucet	Room D262	4:02 AM	Ryan Bergami	<0.001	7/7/16
HS 8	Faucet	Room E285	4:04 AM	Ryan Bergami	0.0016	7/7/16
HS 9	Drinking Fountain	Hallway Fountain	4:07 AM	Ryan Bergami	<0.001	7/7/16
HS 10	Faucet	Room E271A	4:09 AM	Ryan Bergami	<0.001	7/7/16
HS 11	Faucet	Room C236B	4:13 AM	Ryan Bergami	0.0013	7/7/16
HS 12	Faucet	Room C238A	4:16 AM	Ryan Bergami	<0.001	7/7/16
HS 13	Faucet	Room C238	4:18 AM	Ryan Bergami	<0.001	7/7/16
HS 14	Faucet	Room C238	4:19 AM	Ryan Bergami	0.0043	7/7/16
HS 15	Drinking Fountain	Hallway Fountain	4:22 AM	Ryan Bergami	<0.001	7/7/16
HS 16	Drinking Fountain	Hallway Fountain	4:24 AM	Ryan Bergami	<0.001	7/7/16
HS 17	Faucet	Room A218	4:26 AM	Ryan Bergami	0.0012	7/7/16
HS 18	Drinking Fountain	Hallway Fountain	4:29 AM	Ryan Bergami	<0.001	7/7/16
HS 19	Drinking Fountain	North Cafeteria	4:31 AM	Ryan Bergami	<0.001	7/7/16
HS 20	Faucet	Student Support Services	4:33 AM	Ryan Bergami	1.1	6/29/2016
HS 21	Drinking Fountain	Weight Room	4:36 AM	Ryan Bergami	<0.001	7/7/16
HS 22	Drinking Fountain	Pool	4:41 AM	Ryan Bergami	<0.001	7/7/16
HS 23	Drinking Fountain	Boys Locker Room(Blatnick Gym)	4:46 AM	Ryan Bergami	<0.001	7/7/16
HS 24	Drinking Fountain	Boys Team Rooms	4:51 AM	Ryan Bergami	<0.001	7/7/16
HS 25	Drinking Fountain	Boys Team Rooms	4:52 AM	Ryan Bergami	<0.001	7/7/16
HS 26	Drinking Fountain	Hallway Fountain	4:54 AM	Ryan Bergami	<0.001	7/7/16
HS 27	Faucet	Concession Stand	5:00 AM	Ryan Bergami	<0.001	7/7/16
HS 28	Faucet	Room B237F	5:02 AM	Ryan Bergami	<0.001	7/7/16
HS 29	Faucet	Library Work Room	5:06 AM	Ryan Bergami	0.0018	7/7/16
HS 30	Drinking Fountain	Hallway Fountain	5:09 AM	Ryan Bergami	<0.001	7/7/16
HS 31	Drinking Fountain	Hallway Fountain	5:10 AM	Ryan Bergami	<0.001	7/7/16
HS 32	Faucet	Room C240	5:13 AM	Ryan Bergami	<0.001	7/7/16

SCHOOL Niskayuna High School			DATE 6/9/2016			
TAG/ID	DESCRIPTION OF SOURCE	LOCATION	TIME	COLLECTOR	Lead mg/L	Date Analyzed
HS 33	Drinking Fountain	Hallway Fountain	5:15 AM	Ryan Bergami	<0.001	7/7/16
HS 34	Drinking Fountain	Hallway Fountain	5:16 AM	Ryan Bergami	<0.001	7/7/16
HS 35	Faucet	Room C256E	5:18 AM	Ryan Bergami	<0.001	7/7/16
HS 36	Drinking Fountain	Hallway Fountain	5:21 AM	Ryan Bergami	<0.001	7/7/16
HS 37	Drinking Fountain	Hallway Fountain	5:22 AM	Ryan Bergami	<0.001	7/7/16
HS 38	Faucet	Room C442	5:24 AM	Ryan Bergami	<0.001	7/7/16
HS 39	Drinking Fountain	Hallway Fountain	5:25 AM	Ryan Bergami	<0.001	7/7/16
HS 40	Drinking Fountain	Hallway Fountain	5:26 AM	Ryan Bergami	<0.001	7/7/16
HS 41	Drinking Fountain	Hallway Fountain	5:29 AM	Ryan Bergami	<0.001	7/7/16
HS 42	Faucet	Room D309	5:31 AM	Ryan Bergami	0.0016	7/7/16
HS 43	Drinking Fountain	Hallway Fountain	5:33 AM	Ryan Bergami	<0.001	7/7/16
HS 44	Faucet	Room D302	5:35 AM	Ryan Bergami	<0.001	7/7/16
HS 45	Faucet	Kitchen	5:37 AM	Ryan Bergami	0.0023	7/7/16
HS 46	Faucet	Kitchen	5:39 AM	Ryan Bergami	0.003	7/7/16
HS 47	Faucet	Kitchen	5:41 AM	Ryan Bergami	0.0023	7/7/16
HS 48	Faucet	Kitchen	5:44 AM	Ryan Bergami	0.0026	7/7/16
HS 49	Faucet	Room D108E	5:51 AM	Ryan Bergami	<0.001	7/7/16
HS 50	Faucet	Room F135	5:54 AM	Ryan Bergami	<0.001	7/7/16

JH CONSULTING, GROUP, INC  
PO BOX 705  
NEWTONVILLE, NY 12128  
(518) 785-9839

SCHOOL LEAD MONITORING RESULTS

<u>SAMPLE ID</u>	<u>SCHOOL &amp; SAMPLE LOCATION</u>	<u>DATE COLLECTED</u>	<u>LEAD mg/L</u>	<u>Date Analyzed</u> <u>Lead</u>
1606276	GE - 3 Flush	7/28/2016	0.0011	8/6/16
1606275	GE - 3 First Draw	7/28/2016	0.0035	8/6/16
1606277	HS-20 First Draw	7/28/2016	0.0035	8/6/16
1606278	HS-20 Flush	7/28/2016	0.0039	8/6/16

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
HS 51	10/28/2016 07:09	11/22/2016 09:15	10369130001	Lead	43.8	15	ug/L
HS 52	10/28/2016 07:22	11/22/2016 09:22	10369130002	Lead	6.9	15	ug/L
HS 53	10/28/2016 07:50	11/22/2016 09:23	10369130003	Lead	7.8	15	ug/L
HS 54	10/28/2016 07:55	11/22/2016 09:24	10369130004	Lead	4.6	15	ug/L
HS 55	10/28/2016 08:13	11/22/2016 09:25	10369130005	Lead	2.9	15	ug/L
HS 56	10/28/2016 08:21	11/22/2016 09:26	10369130006	Lead	30.4	15	ug/L
HS 57	10/28/2016 08:25	11/22/2016 09:28	10369130007	Lead	4.8	15	ug/L
HS 58	10/28/2016 07:44	11/22/2016 09:29	10369130008	Lead	0.37	15	ug/L
HS 59	10/28/2016 07:37	11/22/2016 09:30	10369130009	Lead	2.5	15	ug/L
HS 60	10/28/2016 05:29	11/22/2016 09:35	10369130010	Lead	<0.10	15	ug/L
HS 61	10/28/2016 06:15	11/22/2016 09:37	10369130011	Lead	0.95	15	ug/L
HS 62	10/28/2016 06:32	11/22/2016 09:39	10369130012	Lead	0.3	15	ug/L
HS 63	10/28/2016 05:34	11/22/2016 09:40	10369130013	Lead	2.2	15	ug/L
HS 64	10/28/2016 05:53	11/22/2016 09:41	10369130014	Lead	0.96	15	ug/L
HS 65	10/28/2016 05:20	11/22/2016 09:43	10369130015	Lead	3.0	15	ug/L
HS 66	10/28/2016 05:24	11/22/2016 09:44	10369130016	Lead	0.81	15	ug/L
HS 67	10/28/2016 05:42	11/22/2016 09:45	10369130017	Lead	2.0	15	ug/L
HS 68	10/28/2016 06:18	11/22/2016 09:46	10369130018	Lead	0.69	15	ug/L
HS 69	10/28/2016 06:20	11/22/2016 09:52	10369130019	Lead	1.5	15	ug/L
HS 70	10/28/2016 06:00	11/22/2016 09:53	10369130020	Lead	0.73	15	ug/L
HS 71	10/28/2016 05:48	11/22/2016 16:28	10369130021	Lead	2.2	15	ug/L
HS 72	10/28/2016 05:49	11/22/2016 16:25	10369130022	Lead	1.0	15	ug/L
HS 73	10/28/2016 05:49	11/22/2016 16:33	10369130023	Lead	0.88	15	ug/L
HS 74	10/28/2016 05:50	11/22/2016 16:34	10369130024	Lead	3.5	15	ug/L
HS 75	10/28/2016 05:51	11/22/2016 16:35	10369130025	Lead	0.95	15	ug/L
HS 76	10/28/2016 06:05	11/22/2016 16:36	10369130026	Lead	2.0	15	ug/L
HS 77	10/28/2016 06:08	11/22/2016 16:37	10369130027	Lead	0.65	15	ug/L
HS 78	10/28/2016 06:08	11/22/2016 16:38	10369130028	Lead	0.71	15	ug/L
HS 79	10/28/2016 05:22	11/22/2016 16:42	10369130029	Lead	0.48	15	ug/L
HS 80	10/28/2016 05:30	11/22/2016 16:43	10369130030	Lead	1.1	15	ug/L
HS 81	10/28/2016 05:38	11/22/2016 16:44	10369130031	Lead	0.78	15	ug/L
HS 82	10/28/2016 05:39	11/22/2016 16:46	10369130032	Lead	2.0	15	ug/L
HS 83	10/28/2016 05:40	11/22/2016 16:47	10369130033	Lead	0.54	15	ug/L
HS 84	10/28/2016 05:51	11/22/2016 16:48	10369130034	Lead	0.55	15	ug/L
HS 85	10/28/2016 05:58	11/22/2016 16:49	10369130035	Lead	0.44	15	ug/L
HS 86	10/28/2016 06:09	11/22/2016 16:51	10369130036	Lead	0.86	15	ug/L
HS 87	10/28/2016 06:09	11/22/2016 16:52	10369130037	Lead	0.72	15	ug/L
HS 88	10/28/2016 06:24	11/22/2016 16:57	10369130038	Lead	0.76	15	ug/L
HS 89	10/28/2016 06:26	11/22/2016 16:58	10369130039	Lead	1.7	15	ug/L
HS 90	10/28/2016 06:27	11/22/2016 16:59	10369130040	Lead	1.2	15	ug/L
HS 93	10/28/2016 07:25	11/21/2016 20:04	10369130041	Lead	12.4	15	ug/L
HS 94	10/28/2016 07:28	11/21/2016 20:09	10369130042	Lead	2.0	15	ug/L
HS 95	10/28/2016 07:30	11/21/2016 20:12	10369130043	Lead	18.4	15	ug/L
HS 96	10/28/2016 07:39	11/21/2016 20:13	10369130044	Lead	3.5	15	ug/L
HS 100	10/28/2016 08:02	11/21/2016 20:15	10369130045	Lead	34.6	15	ug/L

NYSDOH Action Level for Lead of 15 ppb