

SCHOOL Rosendale Elementary School			DATE #####			
TAG/ID	DESCRIPTION OF SOURCE	LOCATION	TIME	COLLECTOR	LEAD mg/L	Date Analyzed Lead
RE 1	Drinking Fountain	Room 103	4:26 AM	Ryan Bergami	0.0017	6/20/16
RE 2	Drinking Fountain	Room 101	4:29 AM	Ryan Bergami	0.0028	6/20/16
RE 3	Drinking Fountain	Room 100	4:32 AM	Ryan Bergami	<0.001	6/20/16
RE 4	Drinking Fountain	Room 106	4:34 AM	Ryan Bergami	0.0018	6/20/16
RE 5	Drinking Fountain	Room 107	4:36 AM	Ryan Bergami	0.0014	6/20/16
RE 6	Drinking Fountain	Room 108	4:38 AM	Ryan Bergami	0.002	6/20/16
RE 7	Drinking Fountain	Room 109	4:40 AM	Ryan Bergami	0.0013	6/20/16
RE 8	Drinking Fountain	Room 110	4:42 AM	Ryan Bergami	0.0015	6/20/16
RE 9	Drinking Fountain	Room 111	4:44 AM	Ryan Bergami	0.0016	6/20/16
RE 10	Faucet	Teachers Lounge	4:46 AM	Ryan Bergami	<0.001	6/20/16
RE 11	Faucet	Room 117	4:48 AM	Ryan Bergami	0.0017	6/20/16
RE 12	Drinking Fountain	Hallway Fountain	4:50 AM	Ryan Bergami	<0.001	6/20/16
RE 13	Drinking Fountain	Room 126	4:52 AM	Ryan Bergami	0.0016	6/20/16
RE 14	Drinking Fountain	Room 129	4:54 AM	Ryan Bergami	0.0013	6/20/16
RE 15	Drinking Fountain	Room 133	4:56 AM	Ryan Bergami	0.0025	6/20/16
RE 16	Drinking Fountain	Hallway Fountain	4:58 AM	Ryan Bergami	0.0038	6/20/16
RE 17	Drinking Fountain	Room 135	5:00 AM	Ryan Bergami	0.0021	6/20/16
RE 18	Drinking Fountain	Room 137	5:02 AM	Ryan Bergami	0.0023	6/20/16
RE 19	Drinking Fountain	Room 140	5:03 AM	Ryan Bergami	0.0051	6/20/16
RE 20	Faucet	Room 139	5:05 AM	Ryan Bergami	0.0012	6/20/16
RE 21	Drinking Fountain	Room 141	5:06 AM	Ryan Bergami	0.0012	6/20/16
RE 22	Drinking Fountain	Room 143	5:08 AM	Ryan Bergami	<0.001	6/20/16
RE 23	Drinking Fountain	Room 144	5:10 AM	Ryan Bergami	<0.001	6/20/16
RE 24	Drinking Fountain	Room 145	5:12 AM	Ryan Bergami	<0.001	6/20/16
RE 25	Drinking Fountain	Room 146	5:14 AM	Ryan Bergami	0.006	6/20/16
RE 26	Drinking Fountain	Hallway Fountain	5:16 AM	Ryan Bergami	<0.001	6/20/16
RE 27	Drinking Fountain	Hallway Fountain	5:17 AM	Ryan Bergami	<0.001	6/20/16
RE 28	Drinking Fountain	Room 154	5:19 AM	Ryan Bergami	<0.001	6/20/16
RE 29	Drinking Fountain	Room 155	5:21 AM	Ryan Bergami	<0.001	6/20/16
RE 30	Drinking Fountain	Room 157	5:23 AM	Ryan Bergami	<0.001	6/20/16
RE 31	Drinking Fountain	Room 156	5:24 AM	Ryan Bergami	<0.001	6/20/16
RE 32	Faucet	Cafeteria Kitchen	5:28 AM	Ryan Bergami	0.013	6/20/16
RE 33	Faucet	Cafeteria Kitchen	5:29 AM	Ryan Bergami	0.0031	6/20/16
RE 34	Faucet	Room 115	5:31 AM	Ryan Bergami	0.0018	6/20/16

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action	Units
RE35	9/30/2016 05:07	10/12/2016 18:14	10365485001	Lead	0.6	15	ug/L
RE36	9/30/2016 05:07	10/12/2016 18:13	10365485002	Lead	2.2	15	ug/L
RE37	9/30/2016 05:08	10/12/2016 18:24	10365485003	Lead	2.8	15	ug/L
RE38	9/30/2016 05:09	10/12/2016 18:25	10365485004	Lead	4.3	15	ug/L
RE39	9/30/2016 05:10	10/12/2016 18:26	10365485005	Lead	1.3	15	ug/L
RE40	9/30/2016 05:11	10/12/2016 18:28	10365485006	Lead	1.2	15	ug/L
RE41	9/30/2016 05:12	10/12/2016 18:29	10365485007	Lead	1.5	15	ug/L
RE42	9/30/2016 05:13	10/12/2016 18:30	10365485008	Lead	1.0	15	ug/L
RE43	9/30/2016 05:14	10/12/2016 18:32	10365485009	Lead	1.2	15	ug/L
RE44	9/30/2016 05:15	10/12/2016 18:33	10365485010	Lead	0.88	15	ug/L
RE45	9/30/2016 05:16	10/12/2016 18:34	10365485011	Lead	1.7	15	ug/L
RE46	9/30/2016 05:16	10/12/2016 18:41	10365485012	Lead	1.6	15	ug/L
RE47	9/30/2016 05:18	10/12/2016 18:42	10365485013	Lead	2.4	15	ug/L
RE48	9/30/2016 05:19	10/12/2016 18:44	10365485014	Lead	1.0	15	ug/L
RE49	9/30/2016 05:20	10/12/2016 18:45	10365485015	Lead	3.9	15	ug/L
RE50	9/30/2016 05:21	10/12/2016 18:46	10365485016	Lead	3.2	15	ug/L
RE51	9/30/2016 05:22	10/12/2016 18:48	10365485017	Lead	1.2	15	ug/L
RE52	9/30/2016 05:23	10/12/2016 18:49	10365485018	Lead	0.99	15	ug/L
RE53	9/30/2016 05:24	10/12/2016 18:50	10365485019	Lead	12.8	15	ug/L
RE54	9/30/2016 05:25	10/12/2016 18:52	10365485020	Lead	2.6	15	ug/L
RE55	9/30/2016 05:26	10/13/2016 12:13	10365485021	Lead	4.0	15	ug/L
RE56	9/30/2016 05:30	10/13/2016 12:22	10365485022	Lead	5.8	15	ug/L
RE57	9/30/2016 05:32	10/13/2016 12:23	10365485023	Lead	2.4	15	ug/L
RE58	9/30/2016 05:33	10/13/2016 12:25	10365485024	Lead	7.0	15	ug/L
RE59	9/30/2016 05:40	10/13/2016 12:26	10365485025	Lead	15.5	15	ug/L
RE60	9/30/2016 05:40	10/13/2016 12:28	10365485026	Lead	1.6	15	ug/L
RE61	9/30/2016 05:40	10/13/2016 12:29	10365485027	Lead	6.9	15	ug/L
RE62	9/30/2016 05:40	10/13/2016 12:30	10365485028	Lead	42.0	15	ug/L
RE63	9/30/2016 05:41	10/13/2016 12:32	10365485029	Lead	2.4	15	ug/L
RE64	9/30/2016 05:41	10/13/2016 12:35	10365485030	Lead	13.0	15	ug/L
RE65	9/30/2016 05:44	10/13/2016 12:37	10365485031	Lead	16.9	15	ug/L
RE66	9/30/2016 05:46	10/13/2016 12:40	10365485032	Lead	5.0	15	ug/L
RE67	9/30/2016 05:47	10/13/2016 12:41	10365485033	Lead	8.1	15	ug/L
RE68	9/30/2016 05:48	10/13/2016 12:42	10365485034	Lead	6.0	15	ug/L
RE69	9/30/2016 05:49	10/13/2016 12:44	10365485035	Lead	3.2	15	ug/L
RE70	9/30/2016 05:50	10/13/2016 12:45	10365485036	Lead	2.3	15	ug/L
RE71	9/30/2016 05:51	10/13/2016 12:46	10365485037	Lead	2.2	15	ug/L
RE72	9/30/2016 05:53	10/13/2016 12:48	10365485038	Lead	2.8	15	ug/L
RE73	9/30/2016 05:54	10/13/2016 12:53	10365485039	Lead	0.97	15	ug/L
RE74	9/30/2016 05:58	10/13/2016 12:55	10365485040	Lead	6.7	15	ug/L
RE75	9/30/2016 05:59	10/13/2016 09:03	10365485041	Lead	2.4	15	ug/L
RE76	9/30/2016 06:00	10/13/2016 09:04	10365485042	Lead	3.1	15	ug/L
RE77	9/30/2016 06:02	10/13/2016 09:07	10365485043	Lead	1.4	15	ug/L
RE78	9/30/2016 06:04	10/13/2016 09:08	10365485044	Lead	2.3	15	ug/L
RE79	9/30/2016 06:04	10/13/2016 09:09	10365485045	Lead	2.1	15	ug/L
RE80	9/30/2016 06:06	10/13/2016 09:11	10365485046	Lead	9.1	15	ug/L
RE81	9/30/2016 06:08	10/13/2016 09:12	10365485047	Lead	8.5	15	ug/L
RE82	9/30/2016 06:10	10/13/2016 09:19	10365485048	Lead	0.41	15	ug/L
RE83	9/30/2016 06:15	10/13/2016 09:20	10365485049	Lead	1.1	15	ug/L
RE84	9/30/2016 06:17	10/13/2016 09:21	10365485050	Lead	1.3	15	ug/L
RE85	9/30/2016 06:21	10/13/2016 12:58	10365485051	Lead	12.9	15	ug/L



100
100 RR
101
103
106
107
108
109
110
111
115
115 RR
119 Café Sink
Womens RR
Mens RR
124
126
129
Kitchen RR
133
135
Gym RR
137
140 sink/fountain
140 Cubby Left
140 Cubby Middle
140 Cubby Right
140 Classroom Right
140 Classroom Middle
140 Classroom Left
141
144
143
146
145
STAFF RR L
STAFF RR R
154
154 BR
155
155 BR
156
156 BR
157
157 BR
spig 157
spig 156
spig 154
spig 126
spig fac
spig 111