

SCHOOL				Van Antwerp Middle School				DATE		6/7/2016	
TAG/ID	DESCRIPTION OF SOURCE			LOCATION			TIME	COLLECTOR	LEAD mg/L	Date Analyzed Lead	
VM 1	Faucet			Room 131 "Faculty"			5:29 AM	Ryan Bergami	0.0022	6/28/16	
VM 2	Drinking Fountain			Entranceway Fountain			5:34 AM	Ryan Bergami	<0.001	6/28/16	
VM 3	Faucet			Room 21 "Lounge"			5:37 AM	Ryan Bergami	0.0034	6/28/16	
VM 4	Drinking Fountain			Hallway Fountain			5:39 AM	Ryan Bergami	<0.001	6/28/16	
VM 5	Faucet			Kitchen Sink			5:44 AM	Ryan Bergami	0.0018	6/28/16	
VM 6	Faucet			Kitchen Sink			5:45 AM	Ryan Bergami	0.0011	6/28/16	
VM 7	Drinking Fountain			Cafeteria			5:48 AM	Ryan Bergami	<0.001	6/28/16	
VM 8	Drinking Fountain			Cafeteria			5:50 AM	Ryan Bergami	<0.001	6/28/16	
VM 9	Faucet			Room 120 "Nurses"			5:53 AM	Ryan Bergami	0.0016	6/28/16	
VM 10	Drinking Fountain			Hallway Fountain			5:55 AM	Ryan Bergami	<0.001	6/28/16	
VM 11	Drinking Fountain			Boys locker room			5:57 AM	Ryan Bergami	<0.001	6/28/16	
VM 12	Drinking Fountain			Girls locker room			6:00 AM	Ryan Bergami	0.0011	6/28/16	
VM 13	Drinking Fountain			Hallway Fountain			6:07 AM	Ryan Bergami	<0.001	6/28/16	
VM 14	Faucet			Room 224			6:11 AM	Ryan Bergami	0.0018	6/28/16	
VM 15	Faucet			Room 224			6:13 AM	Ryan Bergami	0.016	6/28/16	
VM 16	Faucet			Room 224			6:15 AM	Ryan Bergami	0.0048	6/28/16	
VM 17	Faucet			Room 224			6:16 AM	Ryan Bergami	0.0034	6/28/16	
VM 18	Faucet			Room 224			6:18 AM	Ryan Bergami	0.0047	6/28/16	
VM 19	Drinking Fountain			Hallway Fountain			6:20 AM	Ryan Bergami	<0.001	6/28/16	

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
VM 20A Left	10/25/2016 05:22	11/30/2016 03:03	10369769001	Lead	1.3	15	ug/L
VM 22	10/25/2016 05:26	11/30/2016 03:21	10369769002	Lead	1.1	15	ug/L
VM 23A Left	10/25/2016 05:29	11/30/2016 03:24	10369769003	Lead	3.7	15	ug/L
VM 24A Left	10/25/2016 05:32	11/30/2016 03:27	10369769004	Lead	1.5	15	ug/L
VM 25A Left	10/25/2016 05:40	11/30/2016 03:30	10369769005	Lead	0.96	15	ug/L
VM 26A Left	10/25/2016 05:42	11/30/2016 03:33	10369769006	Lead	1.7	15	ug/L
VM 27	10/25/2016 05:53	11/30/2016 03:36	10369769007	Lead	4.4	15	ug/L
VM 28	10/25/2016 05:52	11/30/2016 03:39	10369769008	Lead	2.2	15	ug/L
VM 29	10/25/2016 05:49	11/30/2016 03:42	10369769009	Lead	0.84	15	ug/L
VM 30A Left	10/25/2016 05:56	11/30/2016 03:54	10369769010	Lead	2.0	15	ug/L
VM 31A Left (woman's)	10/25/2016 06:04	11/30/2016 03:57	10369769011	Lead	6.5	15	ug/L
VM 32A Left	10/25/2016 06:12	11/30/2016 04:00	10369769012	Lead	3.6	15	ug/L
VM 33A Left (running)	10/25/2016 06:17	11/30/2016 04:03	10369769013	Lead	0.44	15	ug/L
VM 34A Left	10/25/2016 06:23	11/30/2016 04:06	10369769014	Lead	2.4	15	ug/L
VM 36A Left	10/25/2016 06:34	11/30/2016 04:09	10369769015	Lead	1.3	15	ug/L
VM 37	10/25/2016 06:39	11/30/2016 04:12	10369769016	Lead	70.4	15	ug/L
VM 40	10/25/2016 06:42	11/30/2016 04:15	10369769017	Lead	158	15	ug/L
VM 41	10/25/2016 06:44	11/30/2016 09:10	10369769018	Lead	271	15	ug/L
VM 43	10/25/2016 06:47	11/30/2016 12:07	10369769019	Lead	2,110	15	ug/L
VM 44	10/25/2016 06:48	11/30/2016 09:12	10369769020	Lead	73.5	15	ug/L
VM 20B	10/25/2016 05:22	11/29/2016 11:35	10369769021	Lead	0.64	15	ug/L
VM 23B Center	10/25/2016 05:29	11/29/2016 11:41	10369769022	Lead	2.3	15	ug/L
VM 23C Right	10/25/2016 05:29	11/29/2016 11:42	10369769023	Lead	2.5	15	ug/L
VM 24B Center	10/25/2016 05:33	11/29/2016 11:43	10369769024	Lead	0.92	15	ug/L
VM 24C Right	10/25/2016 05:34	11/29/2016 11:45	10369769025	Lead	5.4	15	ug/L
VM 25B Center Left	10/25/2016 05:40	11/29/2016 11:46	10369769026	Lead	0.48	15	ug/L
VM 25C Right Center	10/25/2016 05:41	11/29/2016 11:47	10369769027	Lead	0.8	15	ug/L
VM 26B Center Left	10/25/2016 05:43	11/29/2016 11:48	10369769028	Lead	1.4	15	ug/L
VM 26C Center Right	10/25/2016 05:43	11/29/2016 11:49	10369769029	Lead	1.3	15	ug/L
VM 26D Right	10/25/2016 05:44	11/29/2016 11:52	10369769030	Lead	1.2	15	ug/L
VM 30B Center	10/25/2016 05:56	11/29/2016 11:53	10369769031	Lead	1.7	15	ug/L
VM 31B Center	10/25/2016 06:05	11/29/2016 11:56	10369769032	Lead	5.1	15	ug/L
VM 31C Right	10/25/2016 06:05	11/29/2016 11:57	10369769033	Lead	4.4	15	ug/L
VM 32B Center	10/25/2016 06:13	11/29/2016 11:58	10369769034	Lead	2.1	15	ug/L
VM 32C Right	10/25/2016 06:13	11/29/2016 11:59	10369769035	Lead	2.3	15	ug/L
VM 33B Center	10/25/2016 06:18	11/29/2016 12:00	10369769036	Lead	0.8	15	ug/L
VM 33C Right	10/25/2016 06:18	11/29/2016 12:01	10369769037	Lead	0.83	15	ug/L
VM 34B Center	10/25/2016 06:24	11/29/2016 12:02	10369769038	Lead	1.5	15	ug/L
VM 34C Right	10/25/2016 06:24	11/29/2016 12:08	10369769039	Lead	3.0	15	ug/L
VM 35D Right	10/25/2016 06:30	11/29/2016 12:09	10369769040	Lead	0.86	15	ug/L
VM 36B Center Left	10/25/2016 06:34	11/21/2016 14:45	10369769041	Lead	1.1	15	ug/L
VM 36C Center Right	10/25/2016 06:35	11/21/2016 14:50	10369769042	Lead	1.2	15	ug/L
VM 36D Right	10/25/2016 06:35	11/21/2016 14:51	10369769043	Lead	1.5	15	ug/L

NYSDOH Action Level for Lead of 15 ppb