

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
BE1	4/22/2021 05:11	5/5/2021 22:57	70170516001	Lead	2.5	15	ug/L
BE1A	4/22/2021 05:11	5/5/2021 23:03	70170516002	Lead	<1.0	15	ug/L
BE2	4/22/2021 05:15	5/5/2021 23:04	70170516003	Lead	1.4	15	ug/L
BE2A	4/22/2021 05:15	5/5/2021 23:05	70170516004	Lead	<1.0	15	ug/L
BE3	4/22/2021 05:16	5/5/2021 23:06	70170516005	Lead	8.0	15	ug/L
BE3A	4/22/2021 05:16	5/5/2021 23:07	70170516006	Lead	<1.0	15	ug/L
BE4	4/22/2021 05:18	5/5/2021 23:08	70170516007	Lead	<1.0	15	ug/L
BE4A	4/22/2021 05:18	5/5/2021 23:09	70170516008	Lead	<1.0	15	ug/L
BE5	4/22/2021 05:20	5/5/2021 23:12	70170516009	Lead	12.2	15	ug/L
BE5A	4/22/2021 05:20	5/5/2021 23:13	70170516010	Lead	2.2	15	ug/L
BE6	4/22/2021 05:22	5/5/2021 23:14	70170516011	Lead	8.2	15	ug/L
BE6A	4/22/2021 05:22	5/5/2021 23:17	70170516012	Lead	1.7	15	ug/L
BE7	4/22/2021 05:24	5/5/2021 23:18	70170516013	Lead	2.3	15	ug/L
BE7A	4/22/2021 05:24	5/5/2021 23:19	70170516014	Lead	2.1	15	ug/L
BE8	4/22/2021 05:25	5/5/2021 23:20	70170516015	Lead	2.0	15	ug/L
BE8A	4/22/2021 05:25	5/5/2021 23:21	70170516016	Lead	3.3	15	ug/L
BE9	4/22/2021 05:27	5/5/2021 23:24	70170516017	Lead	2.7	15	ug/L
BE10	4/22/2021 05:29	5/5/2021 23:25	70170516018	Lead	<1.0	15	ug/L
BE10A	4/22/2021 05:29	5/5/2021 23:26	70170516019	Lead	<1.0	15	ug/L
BE82	4/22/2021 05:34	5/5/2021 23:27	70170516020	Lead	3.7	15	ug/L
BE82A	4/22/2021 05:34	5/5/2021 23:30	70170516021	Lead	<1.0	15	ug/L
BE83	4/22/2021 05:35	5/5/2021 23:33	70170516022	Lead	11.7	15	ug/L
BE83A	4/22/2021 05:35	5/5/2021 23:36	70170516023	Lead	1.3	15	ug/L
BE28-001	4/22/2021 05:40	5/5/2021 23:37	70170516024	Lead	3.5	15	ug/L
BE28-002	4/22/2021 05:40	5/5/2021 23:38	70170516025	Lead	3.8	15	ug/L
BE28-003	4/22/2021 05:40	5/5/2021 23:39	70170516026	Lead	2.4	15	ug/L
BE28-004	4/22/2021 05:40	5/5/2021 23:40	70170516027	Lead	10.4	15	ug/L
BE28-005	4/22/2021 05:40	5/5/2021 23:41	70170516028	Lead	6.8	15	ug/L
BE28-006	4/22/2021 05:40	5/5/2021 23:42	70170516029	Lead	30.3	15	ug/L
BE12	4/22/2021 05:49	5/5/2021 23:43	70170516030	Lead	<1.0	15	ug/L
BE12A	4/22/2021 05:49	5/5/2021 23:44	70170516031	Lead	<1.0	15	ug/L
BE83	4/22/2021 05:54	5/5/2021 23:49	70170516032	Lead	8.6	15	ug/L
BE15	4/22/2021 05:56	5/5/2021 23:50	70170516033	Lead	<1.0	15	ug/L
BE15A	4/22/2021 05:56	5/5/2021 23:51	70170516034	Lead	<1.0	15	ug/L
BE15B	4/22/2021 05:56	5/5/2021 23:53	70170516035	Lead	<1.0	15	ug/L
BE16	4/22/2021 05:59	5/5/2021 23:54	70170516036	Lead	<1.0	15	ug/L
BE16A	4/22/2021 05:59	5/5/2021 23:55	70170516037	Lead	<1.0	15	ug/L
BE16B	4/22/2021 05:59	5/5/2021 23:56	70170516038	Lead	<1.0	15	ug/L
BE18	4/22/2021 06:02	5/5/2021 23:57	70170516039	Lead	<1.0	15	ug/L
BE18A	4/22/2021 06:02	5/5/2021 23:58	70170516040	Lead	<1.0	15	ug/L
BE18B	4/22/2021 06:02	5/6/2021 00:02	70170516041	Lead	2.9	15	ug/L
BE20	4/22/2021 06:04	5/6/2021 00:05	70170516042	Lead	<1.0	15	ug/L
BE20A	4/22/2021 06:04	5/6/2021 00:06	70170516043	Lead	<1.0	15	ug/L
BE20B	4/22/2021 06:04	5/6/2021 00:08	70170516044	Lead	<1.0	15	ug/L
BE21	4/22/2021 06:06	5/6/2021 00:09	70170516045	Lead	1.4	15	ug/L
BE21A	4/22/2021 06:06	5/6/2021 00:10	70170516046	Lead	<1.0	15	ug/L
BE21B	4/22/2021 06:06	5/6/2021 00:12	70170516047	Lead	1.6	15	ug/L
BE19	4/22/2021 06:10	5/6/2021 00:14	70170516048	Lead	24.7	15	ug/L

BE19A	4/22/2021 06:10	5/6/2021 00:15	70170516049	Lead	2.0	15	ug/L
BE17	4/22/2021 06:12	5/6/2021 00:16	70170516050	Lead	35.2	15	ug/L
BE17A	4/22/2021 06:12	5/6/2021 00:17	70170516051	Lead	2.2	15	ug/L
BE14	4/22/2021 06:14	5/6/2021 00:20	70170516052	Lead	10.1	15	ug/L
BE14A	4/22/2021 06:14	5/6/2021 00:21	70170516053	Lead	2.0	15	ug/L
BE84	4/22/2021 06:16	5/6/2021 00:22	70170516054	Lead	3.0	15	ug/L
BE84A	4/22/2021 06:16	5/6/2021 00:25	70170516055	Lead	8.5	15	ug/L
BE13	4/22/2021 06:18	5/6/2021 00:26	70170516056	Lead	<1.0	15	ug/L
BE13A	4/22/2021 06:18	5/6/2021 00:27	70170516057	Lead	<1.0	15	ug/L
BE24	4/22/2021 06:23	5/6/2021 00:28	70170516058	Lead	11.2	15	ug/L
BE24A	4/22/2021 06:23	5/6/2021 00:29	70170516059	Lead	4.9	15	ug/L
BE24B	4/22/2021 06:23	5/6/2021 00:30	70170516060	Lead	1.5	15	ug/L
BE22	4/22/2021 06:26	5/6/2021 08:53	70170516061	Lead	<1.0	15	ug/L
BE23	4/22/2021 06:26	5/6/2021 08:56	70170516062	Lead	<1.0	15	ug/L
BE25	4/22/2021 06:28	5/6/2021 08:57	70170516063	Lead	5.4	15	ug/L
BE25A	4/22/2021 06:28	5/6/2021 08:58	70170516064	Lead	1.4	15	ug/L
BE25B	4/22/2021 06:28	5/6/2021 08:59	70170516065	Lead	1.9	15	ug/L
BE26	4/22/2021 06:30	5/6/2021 09:00	70170516066	Lead	7.9	15	ug/L
BE26A	4/22/2021 06:30	5/6/2021 09:03	70170516067	Lead	1.7	15	ug/L
BE26B	4/22/2021 06:30	5/6/2021 09:04	70170516068	Lead	<1.0	15	ug/L
BE27	4/22/2021 06:33	5/6/2021 09:05	70170516069	Lead	<1.0	15	ug/L
BE27A	4/22/2021 06:33	5/6/2021 09:06	70170516070	Lead	<1.0	15	ug/L
BE27B	4/22/2021 06:33	5/6/2021 09:07	70170516071	Lead	1.7	15	ug/L
BE74	4/22/2021 06:37	5/6/2021 09:10	70170516072	Lead	1.2	15	ug/L
BE74A	4/22/2021 06:37	5/6/2021 09:11	70170516073	Lead	1.8	15	ug/L
BE74B	4/22/2021 06:37	5/6/2021 09:12	70170516074	Lead	2.3	15	ug/L
BE85	4/22/2021 06:43	5/6/2021 09:15	70170516075	Lead	2.2	15	ug/L
BE86	4/22/2021 06:44	5/6/2021 09:16	70170516076	Lead	5.4	15	ug/L
BE87	4/22/2021 06:49	5/6/2021 09:17	70170516077	Lead	1.5	15	ug/L
BE88	4/22/2021 06:50	5/6/2021 09:18	70170516078	Lead	2.5	15	ug/L
BE89	4/22/2021 06:53	5/6/2021 09:19	70170516079	Lead	2.1	15	ug/L
BE89A	4/22/2021 06:53	5/6/2021 09:20	70170516080	Lead	2.5	15	ug/L
BE89B	4/22/2021 06:53	5/6/2021 09:23	70170516081	Lead	1.4	15	ug/L

NYSDOH Action Level for Lead of 15 ppb