

Sample Identification # and Location	Location Info	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action	Units
HE-1	Hallway Drinking Fountain across from Rm 221	6/14/2024 05:09	6/25/2024 12:30	70301656001	Lead	7.9	5	ug/L
HE-2		6/14/2024 05:10	6/25/2024 12:34	70301656002	Lead	<1.0	5	ug/L
HE-4		6/14/2024 05:20	6/25/2024 12:39	70301656003	Lead	3.0	5	ug/L
HE-4A		6/14/2024 05:20	6/25/2024 12:40	70301656004	Lead	1.3	5	ug/L
HE-5		6/14/2024 05:21	6/25/2024 12:45	70301656005	Lead	2.1	5	ug/L
HE-5A		6/14/2024 05:21	6/25/2024 12:46	70301656006	Lead	1.2	5	ug/L
HE-6		6/14/2024 05:22	6/25/2024 12:48	70301656007	Lead	1.1	5	ug/L
HE-6A		6/14/2024 05:22	6/25/2024 12:50	70301656008	Lead	2.4	5	ug/L
HE-7		6/14/2024 05:26	6/25/2024 12:51	70301656009	Lead	2.7	5	ug/L
HE-7A		6/14/2024 05:26	6/25/2024 12:53	70301656010	Lead	<1.0	5	ug/L
HE-8		6/14/2024 05:27	6/25/2024 12:54	70301656011	Lead	1.5	5	ug/L
HE-8A		6/14/2024 05:27	6/25/2024 12:56	70301656012	Lead	1.0	5	ug/L
HE-9		6/14/2024 05:29	6/25/2024 12:57	70301656013	Lead	1.4	5	ug/L
HE-9A		6/14/2024 05:29	6/25/2024 12:59	70301656014	Lead	1.6	5	ug/L
HE-10		6/14/2024 05:31	6/25/2024 13:04	70301656015	Lead	2.1	5	ug/L
HE-10A		6/14/2024 05:31	6/25/2024 13:05	70301656016	Lead	1.7	5	ug/L
HE-11		6/14/2024 05:35	6/25/2024 13:10	70301656017	Lead	2.8	5	ug/L
HE-11A		6/14/2024 05:35	6/25/2024 13:14	70301656018	Lead	3.0	5	ug/L
HE-12	Room 203 Drinking Fountain	6/14/2024 05:37	6/25/2024 13:22	70301656019	Lead	53.1	5	ug/L
HE-12A		6/14/2024 05:37	6/25/2024 13:24	70301656020	Lead	1.7	5	ug/L
HE-13		6/14/2024 05:38	6/25/2024 13:25	70301656021	Lead	3.5	5	ug/L
HE-13A		6/14/2024 05:38	6/25/2024 13:27	70301656022	Lead	1.8	5	ug/L
HE-14		6/14/2024 05:40	6/25/2024 13:28	70301656023	Lead	<1.0	5	ug/L
HE-14A		6/14/2024 05:40	6/25/2024 13:30	70301656024	Lead	<1.0	5	ug/L
HE-15		6/14/2024 05:43	6/25/2024 13:31	70301656025	Lead	<1.0	5	ug/L
HE-15A		6/14/2024 05:43	6/25/2024 13:33	70301656026	Lead	<1.0	5	ug/L
HE-16		6/14/2024 05:45	6/25/2024 13:34	70301656027	Lead	<1.0	5	ug/L
HE-16A		6/14/2024 05:45	6/25/2024 13:36	70301656028	Lead	<1.0	5	ug/L
HE-21		6/14/2024 05:54	6/25/2024 13:41	70301656029	Lead	4.2	5	ug/L
HE-22		6/14/2024 05:52	6/25/2024 13:42	70301656030	Lead	3.4	5	ug/L
HE-22A	Room 120 Classroom Sink	6/14/2024 05:52	6/25/2024 13:44	70301656031	Lead	5.3	5	ug/L
HE-23		6/14/2024 05:50	6/25/2024 13:45	70301656032	Lead	<1.0	5	ug/L
HE-23A		6/14/2024 05:50	6/25/2024 13:47	70301656033	Lead	<1.0	5	ug/L
HE-24		6/14/2024 06:30	6/25/2024 13:48	70301656034	Lead	<1.0	5	ug/L
HE-25		6/14/2024 06:30	6/25/2024 13:50	70301656035	Lead	<1.0	5	ug/L
HE-26		6/14/2024 06:34	6/25/2024 13:52	70301656036	Lead	<1.0	5	ug/L
HE-27		6/14/2024 06:34	6/25/2024 13:59	70301656037	Lead	<1.0	5	ug/L
HE-33		6/14/2024 05:07	6/25/2024 14:04	70301656038	Lead	<1.0	5	ug/L
HE-33A		6/14/2024 05:07	6/25/2024 14:09	70301656039	Lead	<1.0	5	ug/L
HE-34	Kitchen Sink	6/14/2024 05:04	6/25/2024 14:10	70301656040	Lead	5.1	5	ug/L
HE-34A		6/14/2024 05:04	6/25/2024 14:12	70301656041	Lead	2.9	5	ug/L
HE-35	Kitchen Sink by clock	6/14/2024 05:05	6/25/2024 14:13	70301656042	Lead	109	5	ug/L
NHE-10		6/14/2024 05:57	6/25/2024 14:18	70301656043	Lead	<1.0	5	ug/L
NHE-10A		6/14/2024 05:57	6/25/2024 14:19	70301656044	Lead	1.4	5	ug/L
NHE-011		6/14/2024 05:15	6/25/2024 14:21	70301656045	Lead	1.2	5	ug/L
NHE-012		6/14/2024 05:15	6/25/2024 14:22	70301656046	Lead	<1.0	5	ug/L
NHE-040		6/14/2024 06:04	6/25/2024 14:24	70301656047	Lead	<1.0	5	ug/L
NHE-040A		6/14/2024 06:04	6/25/2024 14:26	70301656048	Lead	<1.0	5	ug/L
NHE-041		6/14/2024 06:07	6/25/2024 14:27	70301656049	Lead	<1.0	5	ug/L
NHE-041A		6/14/2024 06:07	6/25/2024 14:29	70301656050	Lead	<1.0	5	ug/L
NHE-042		6/14/2024 06:09	6/25/2024 14:30	70301656051	Lead	3.8	5	ug/L
NHE-046		6/14/2024 06:15	6/25/2024 14:32	70301656052	Lead	<1.0	5	ug/L
NHE-046A		6/14/2024 06:15	6/25/2024 14:36	70301656053	Lead	<1.0	5	ug/L
NHE-048		6/14/2024 06:17	6/25/2024 14:38	70301656054	Lead	<1.0	5	ug/L
NHE-048A		6/14/2024 06:17	6/25/2024 14:39	70301656055	Lead	<1.0	5	ug/L
NHE-050		6/14/2024 06:20	6/25/2024 14:41	70301656056	Lead	<1.0	5	ug/L
NHE-050A		6/14/2024 06:20	6/25/2024 14:46	70301656057	Lead	<1.0	5	ug/L

NHE-052		6/14/2024 06:24	6/25/2024 14:50	70301656058	Lead	<1.0	5	ug/L
NHE-052A		6/14/2024 06:24	6/25/2024 14:58	70301656059	Lead	<1.0	5	ug/L
NHE-054		6/14/2024 06:26	6/25/2024 14:59	70301656060	Lead	<1.0	5	ug/L
NHE-054A		6/14/2024 06:26	6/25/2024 15:01	70301656061	Lead	<1.0	5	ug/L
NHE-008A	Library Bathroom Sink	6/14/2024 05:17	6/25/2024 15:03	70301656062	Lead	16.7	5	ug/L
NHE-066		6/14/2024 06:37	6/25/2024 15:04	70301656063	Lead	<1.0	5	ug/L
NHE-066A		6/14/2024 06:37	6/25/2024 15:06	70301656064	Lead	<1.0	5	ug/L

NYSDOH Action Level for Lead In Schools of 5 ppb