

| Sample Identification # and Location | Location Info                  | Date/Time Collected | Date/Time Analyzed | Container ID | Analyte | Results | NYSDOH Action | Units |
|--------------------------------------|--------------------------------|---------------------|--------------------|--------------|---------|---------|---------------|-------|
| 1M-1                                 |                                | 6/25/2024 11:10     | 7/9/2024 12:37     | 70302922001  | Lead    | <1.0    | 5             | ug/L  |
| 1M-1A                                |                                | 6/25/2024 11:10     | 7/9/2024 12:39     | 70302922002  | Lead    | <1.0    | 5             | ug/L  |
| 1M-3A                                |                                | 6/25/2024 11:13     | 7/9/2024 12:40     | 70302922003  | Lead    | <1.0    | 5             | ug/L  |
| 1M-3B                                |                                | 6/25/2024 11:13     | 7/9/2024 12:42     | 70302922004  | Lead    | <1.0    | 5             | ug/L  |
| 1M-4                                 |                                | 6/25/2024 11:18     | 7/9/2024 12:43     | 70302922005  | Lead    | <1.0    | 5             | ug/L  |
| 1M-5A                                |                                | 6/25/2024 11:18     | 7/9/2024 12:45     | 70302922006  | Lead    | <1.0    | 5             | ug/L  |
| 1M-5B                                |                                | 6/25/2024 11:18     | 7/9/2024 12:46     | 70302922007  | Lead    | <1.0    | 5             | ug/L  |
| 1M-6                                 |                                | 6/25/2024 11:20     | 7/9/2024 12:48     | 70302922008  | Lead    | <1.0    | 5             | ug/L  |
| 1M-7A                                |                                | 6/25/2024 11:20     | 7/9/2024 12:53     | 70302922009  | Lead    | <1.0    | 5             | ug/L  |
| 1M-7B                                |                                | 6/25/2024 11:20     | 7/9/2024 12:54     | 70302922010  | Lead    | <1.0    | 5             | ug/L  |
| 1M-8                                 |                                | 6/25/2024 11:25     | 7/9/2024 12:56     | 70302922011  | Lead    | 1.3     | 5             | ug/L  |
| 1M-9A                                |                                | 6/25/2024 11:27     | 7/9/2024 13:00     | 70302922012  | Lead    | <1.0    | 5             | ug/L  |
| 1M-9B                                |                                | 6/25/2024 11:27     | 7/9/2024 13:05     | 70302922013  | Lead    | <1.0    | 5             | ug/L  |
| 1M-10                                | Kitchen Sink by Walk-In Cooler | 6/25/2024 11:30     | 7/9/2024 13:13     | 70302922014  | Lead    | 6.6     | 5             | ug/L  |
| 1M-11A                               |                                | 6/25/2024 11:32     | 7/9/2024 13:14     | 70302922015  | Lead    | 3.4     | 5             | ug/L  |
| 1M-11B                               | Left Kitchen Sink (Pot Wash)   | 6/25/2024 11:32     | 7/9/2024 13:16     | 70302922016  | Lead    | 6.9     | 5             | ug/L  |
| 1M-12                                |                                | 6/25/2024 11:35     | 7/9/2024 13:17     | 70302922017  | Lead    | <1.0    | 5             | ug/L  |
| 1M-13A                               |                                | 6/25/2024 11:35     | 7/9/2024 13:19     | 70302922018  | Lead    | <1.0    | 5             | ug/L  |
| 1M-13B                               |                                | 6/25/2024 11:35     | 7/9/2024 13:21     | 70302922019  | Lead    | <1.0    | 5             | ug/L  |
| 1M-14                                |                                | 6/25/2024 11:37     | 7/9/2024 13:22     | 70302922020  | Lead    | <1.0    | 5             | ug/L  |
| 1M-15A                               |                                | 6/25/2024 11:37     | 7/9/2024 13:24     | 70302922021  | Lead    | <1.0    | 5             | ug/L  |
| 1M-15B                               |                                | 6/25/2024 11:37     | 7/9/2024 13:25     | 70302922022  | Lead    | <1.0    | 5             | ug/L  |

NYSDOH Action Level for Lead In Schools of 5 ppb